


ENGINEERING BULLETIN EJ-1091

SAMPLE ANCHOR LOADING CALCULATIONS



**ADVANCED
THERMAL
SYSTEMS, INC.**

15 ENTERPRISE DRIVE/LANCASTER, NEW YORK
PHONE: 716/681-1800 FAX: 716/681-0228

SUPPLEMENT TO
PAGES 18 & 19 OF
BULLETIN TP2-790



The following examples have been prepared to assist those engineers responsible for the design of anchors located in pipelines which utilize slip type expansion joints manufactured by Advanced Thermal Systems Inc. (ATS). These sample calculations supplement the information provided on pages 18 & 19 of ATS Bulletin TP2-790. The following design conditions have been selected for the calculations:

Flowing Media: Saturated Steam @ 388°F

$$p = P_{\text{design}} = 200 \text{ psig}$$

$$D_1 = 10 \text{ in.} \quad L_2 = 100 \text{ ft.}$$

$$D_2 = 8 \text{ in} \quad L_3 = 215 \text{ ft.}$$

$$L = 200 \text{ ft.} \quad K = 600 \text{ lb/in. of Dia.}$$

$$L_1 = 120 \text{ ft.} \quad \theta = 30^\circ$$

- The piping is to be supported on ATS low friction slide supports. Multiply F_s in Table 5 by 0.45. Refer to Note 3 under Table 5 on Page 18 of Bulletin TP2-790
- The expansion joint is packed with Teflon/Asbestos packing.

TABLE 5
ANCHOR CALCULATION VALUES

| Nominal Pipe Size D | Expansion Joint | | | Pipe Supports | |
|---------------------------|---------------------------------------|---|----------|-------------------------------|-------|
| | Thrust Area a = in ² | Packing Friction | | Support Friction | |
| | | F _c = lbs. (K x D) - *Note 1 | | F _s = lbs./100 ft. | |
| | | Teflon/Asbestos | Graphite | Water | Steam |
| 1-1/2" | 2.8 | 900 | 1500 | 215 | 185 |
| 2" | 4.4 | 1200 | 2000 | 270 | 220 |
| 2-1/2" | 6.5 | 1500 | 2500 | 390 | 320 |
| 3" | 9.6 | 1800 | 3000 | 485 | 370 |
| 4" | 15.9 | 2400 | 4000 | 735 | 545 |
| 5" | 24.3 | 3000 | 5000 | 1005 | 700 |
| 6" | 34.5 | 3600 | 6000 | 1315 | 880 |
| 8" | 58.4 | 4800 | 8000 | 2030 | 1275 |
| 10" | 90.8 | 6000 | 10000 | 3000 | 1805 |
| 12" | 127.7 | 7200 | 12000 | 3900 | 2180 |
| 14" | 153.9 | 8400 | 14000 | 4500 | 2385 |
| 16" | 201.0 | 9600 | 16000 | 5500 | 2720 |
| 18" | 254.5 | 10800 | 18000 | 6710 | 3160 |
| 20" | 314.0 | 12000 | 20000 | 7920 | 3506 |
| 24" | 452.0 | 14400 | 24000 | 10770 | 4330 |

*See Page 18 of TP2-790 for notes under Table 5

The piping system has been divided into individual expanding segments by means of anchors - **MAIN** or **INTERMEDIATE**. The forces on an intermediate anchor can calculate out to be zero when the pipe diameter and length of pipe is the same on both sides of the anchor and the number and type of guides in both sections are the same. The pipeline will heat up gradually from one end, thereby causing one of the pipe sections to expand before the other. It is, therefore, considered good practice to design the anchor to resist the force exerted by one of the two pipe sections. See calculations for Anchors A₂, A₃, and A_{7(Y-Y)}.

NOTES

1. It is recommended that a transient load factor of 15% be added to all calculated anchor loads to allow for system pressure surges and or other unknown conditions which may occur during the operating life of the system.
2. The centrifugal force at Anchors A₄ and A₅ has not been considered in the calculations shown. For steam applications this force is quite low and can be accounted for by adding 5% minimum load factor. Refer to page 18 of Bulletin TP2-790 for formula if actual calculation is desired.
3. The anchors A₆, A₇, and A₈ must be designed to resist the forces and moments due to the branch connections. The net loading on the anchor is determined by a summation of the moments about the anchor and the vector sum of the forces acting upon it. Installations at a branch connection require that the calculated force and moment be provided to ATS so that the anchor can be adequately designed
4. The calculated stress levels of the anchors must be within the allowable code limits to satisfactorily accommodate the higher loads which will be encountered during a hydrotest.



MAIN ANCHORS

$$F_{A1} = F_P + F_C + F_S (L)$$

$$F_P = p \times a_1$$

$$= 200 \text{ psig} \times 90.8 \text{ in}^2$$

$$= 18,160 \text{ lbs.}$$

$$F_{A1} = 18,160 \text{ lbs} + 6000 \text{ lbs} +$$

$$(812 \text{ lbs}/100 \text{ ft}) \times 200 \text{ ft}$$

$$= 25,784 \text{ lbs} \quad \times \leftarrow F_{A1}$$

WHERE:

F_{A1} = FORCE AT ANCHOR A_1

F_P = Pressure Force
 $a_1 = 90.8 \text{ in}^2$ (From Table 5)

F_C = Force to compress
 $= 6,000 \text{ lbs}$ (10" Dia. - Table 5)

F_S = Support Friction
 $= 1805 \text{ lbs}/100 \text{ ft} \times .45$
 $= 812 \text{ lbs}/100 \text{ ft}$

See Note 3 under Table 5 on Page 18 of Bulletin TP2-790

$$F_{A4} = (F_1 + F_2) \times \frac{\sin \theta}{2}$$

$$F_1 = F_2 = F_P + F_C$$


$$F_{A4} = 2(F_P + F_C) \times \sin(\theta/2)$$

$$= 2(18,160 \text{ lbs} + 6,000 \text{ lbs}) \times \sin(30^\circ/2)$$

$$= 12,506 \text{ lbs}$$

F_{A4} = FORCE AT ANCHOR A_4

$$\theta = 90 - \frac{\theta}{2}$$



$$F_{A5} = \sqrt{F_3^2 + F_4^2}$$

$$F_3 = F_P + F_C + F_S (L_2)$$

$$= 18,160 \text{ lbs} + 6000 \text{ lbs} +$$

$$(812 \text{ lbs}/100 \text{ ft}) \times 100 \text{ ft}$$

$$F_3 = 24,972 \text{ lbs}$$

$$F_4 = F_P + F_C$$


$$= 18,160 \text{ lbs} + 6,000 \text{ lbs}$$

$$= 24,160 \text{ lbs}$$

$$F_{A5} = \sqrt{24,972^2 \text{ lbs} + 24,160^2 \text{ lbs}}$$

$$= 34,746 \text{ lbs}$$

F_{A5} = FORCE AT ANCHOR A_5



See Note 2 on Page 2 for centrifugal force at A_5

$$F_{A6} = F_5 - F_6$$

$$F_5 = F_P + F_C + F_S (L_3)$$

$$= 18,160 \text{ lbs} + 6,000 \text{ lbs} +$$

$$(812 \text{ lbs}/100 \text{ ft}) \times 215 \text{ ft}$$

$$= 25,906 \text{ lbs}$$

$$F_6 = F_P + F_C + F_S (L_3)$$

$$F_P = p \times a_2$$

$$= 200 \text{ psig} \times 58.4 \text{ in}^2$$

$$= 11,680 \text{ lbs}$$

Cont'd. on Page 4

F_{A6} = FORCE AT ANCHOR A_6
(Y-Y) Direction

Note:

Total loading on A_6 must consider moment in (x-x) direction due to branch line. See Note 3 on Page 2

$D_2 = 8 \text{ in.}$

$a_2 = 58.4 \text{ in}^2$ (From Table 5 - Page 2)

$F_S = 1275 \text{ lb}/100 \text{ ft} \times 0.45$
 $= 574 \text{ lb}/100 \text{ ft}$


See Note 3 under Table 5, Page 18 of Bulletin TP2-790



$$F_6 = 11,680 \text{ lbs} + 4800 \text{ lbs} + (574 \text{ lbs}/100 \text{ ft}) \times 215 \text{ ft} = 17,714 \text{ lbs}$$


$$F_{A6} = 25,906 \text{ lbs} - 17,714 \text{ lbs} = 8,192 \text{ lbs}$$

$$F_C = 4,800 \text{ lbs (8" Dia - Table 5)}$$



$$F_{A7} = F_C$$

$$F_{A7} = 4,800 \text{ lbs}$$



F_{A7} = FORCE AT ANCHOR A_7
(Y-Y) Direction

Anchor A_7 is considered a MAIN anchor due to the moment in the (x-x) direction from the branch line.

See Note 3 on Page 2

$$F_{A8} = F_C + F_S (L_3) = 4,800 \text{ lbs} + (574 \text{ lbs}/100 \text{ ft}) \times 215 \text{ ft} = 6,034 \text{ lbs}$$



WITH VALVE V_2 OPENED

F_{A8} = FORCE AT ANCHOR A_8
(Y-Y) Direction

$$F_{A8} = F_P + F_C + F_S (L_3) = 11,680 \text{ lbs} + 4,800 \text{ lbs} + (574 \text{ lb}/100 \text{ ft}) \times 215 \text{ ft} = 17,714 \text{ lbs}$$

WITH VALVE V_2 CLOSED

F_{A8} = FORCE AT ANCHOR A_8
(Y-Y) Direction

Total loading on Anchor A_8 must consider the moment in the (X-X) direction due to the branch line. See Note 3 on Page 2.

$$F_{A9} = F_P + F_C = 11,680 \text{ lbs} + 4,800 \text{ lbs} = 16,480 \text{ lbs}$$



F_{A9} = FORCE AT ANCHOR A_9

WITH VALVE V_2 OPENED

$$F_{A9} = 0 \text{ lbs}$$

WITH VALVE V_2 CLOSED

INTERMEDIATE ANCHORS

$$F_{A2} = F_C = 6,000 \text{ lbs}$$



F_{A2} = FORCE AT ANCHOR A_2

$$F_{A3} = F_C + F_S (L) = 6,000 \text{ LBS} + (812 \text{ lbs}/100 \text{ ft}) \times 200 \text{ ft} = 7,624 \text{ lbs}$$



F_{A3} = FORCE AT ANCHOR A_3